



State of Emissions

- New Regulations
- NOx Reduction Theory
- NOx Reduction Strategies

Seaworthy Systems, Inc.

- **Founded in 1973**
- **Principal Founders Came From P&W / TP&M**
- **Conducted Numerous Studies for the Maritime Administration Regarding Gas Turbine Installations**
- **Conducted Numerous Studies for Emissions Mitigation from Fossil Fuel Power Generation**

Seaworthy Systems, Inc.

- **Developed HPWI Skid with PEPCO in 1995**
 - **> 60 systems in operation**
- **Specialty Fuel Filtration & Forwarding Systems for Gas Turbines**
- **Specialty Lube Oil Filtration System for Varnish removal (esp. applicable for Frame 5/7)**
- **Gas Turbine Inlet Air Fogging System**

Regulations



Memorandum of Understanding Among the States of the Ozone Transport Commission Concerning the Incorporation of High Electrical Demand Day Emission Reduction Strategies into Ozone Attainment State Implementation Planning

Connecticut

Delaware

District of Columbia

Maine

Maryland

Massachusetts

New Hampshire

New Jersey

New York

Whereas the Ozone Transport Commission (OTC) was established under Sections 176A and 184 of the federal Clean Air Act (CAA) to ensure the development and implementation of regional strategies to reduce ground-level ozone to healthful levels; and

Whereas the adverse health effects of ground-level ozone are well documented, and in spite of significant reductions of ozone precursor emissions achieved to date as a result of our NO_x MOU of 1994, the US

Envi
expe
the
caus
regio

Whe
have
thes
pollu

Therefore, be it **RESOLVED** that

The OTC States identified in the following table commit to pursue the following **reductions in NO_x emissions associated with HEDD units on high electrical demand days during the ozone season**; such reductions to be achieved **beginning** with the **2009** ozone season or as soon as feasible thereafter, but **no later than 2012**:



Seaworthy Industrial Systems, Inc.
Part of the Rolls-Royce Group

PEPCO Plainville Electrical
Products Company
Engineers, Designers and Manufacturers
of Control Systems Since 1922

HEDD NO_x Differential

	Total NO _x	Total NO _x	Increased	Percent
STATE	6/4/2005	7/26/2005	Tons of NO _x	Change
MD	84	218	134	160
NY	110	377	267	243
PA	233	404	171	73
CT	10	54	44	440
MA	47	74	27	57
DE	14	58	44	314
NJ	52	163	111	213
TOTAL	550	1348	798	145



Seaworthy Industrial Systems, Inc.
Part of the Rolls-Royce Group



PEPCO
Engineers, Designers and Manufacturers
of Control Systems

Plainville Electrical
Products Company
Since 1922

Regulations



Memorandum of Understanding Among the States of the Ozone Transport Commission Concerning the Incorporation of High Electrical Demand Day Emission Reduction Strategies into Ozone Attainment State Implementation Planning

Connecticut

Delaware

District of Columbia

Maine

Maryland

Massachusetts

New Hampshire

New Jersey

New York

Whereas the Ozone Transport Commission (OTC) was established under Sections 176A and 184 of the federal Clean Air Act (CAA) to ensure the development and implementation of regional strategies to reduce ground level ozone

When documenting emissions from environmental expected the need to cause regional

When have these pollutants

State	NOx (tons per day)	Percent Reduction from HEDD Units
CT	11.7	25%
DE	7.3	20%
MD	23.5	32%
NJ	19.8	28%
NY	50.8	27%
PA	21.8	32%
Total	134.9	

Furthermore, that such reduction commitment will be included in each of the several states' 8-hour ozone attainment State Implementation Plan submissions to EPA due in June 2007; and



Seaworthy Industrial Systems, Inc.
Part of the Rolls-Royce Group

PEPCO Plainville Electrical
Products Company
Engineers, Designers and Manufacturers
of Control Systems Since 1922

Regulations

Model Rule for Additional Nitrogen Oxides (NOx) Control Measures



Connecticut

Delaware

District of Columbia

Maine

Maryland

Massachusetts

New Hampshire

New Jersey

New York


- (2) For a simple cycle combustion turbine:
- For a **gas-fired turbine** without oil back-up, 2.2 pounds of NOx per MWh (**55 ppmvd**, corrected to 15% O₂);
 - For an **oil-fired turbine**, 3.0 pounds of NOx per MWh (**75 ppmvd**, corrected to 15% O₂), and



Seaworthy Industrial Systems, Inc.
Part of the Rolls-Royce Group




High Electric Demand Day Units



17

NOx Production vs. Firing Temp



NOx Reduction Strategies


- Remove NOx from exhaust after production
- Reduce NOx production
- Combination of Removal & Reduction

NOx Removal

SCR System

- Uses Ammonia/Urea to remove NOx
- Pros
 - Can remove NOx to very low levels
 - Does NOT increase CO levels
- Cons
 - Very Large space requirements
 - Requires a separate Ammonia Delivery system
 - Requires an Ammonia/Urea Storage Tank
 - Requires Ammonia/Urea Resupply

SCR Screen



NOx Removal

SCR System Installation



NOx Reduction

- Dry Low NOx (DLN)
 - No viable solution has yet been engineered for FT4s
- High Pressure Water Injection (HPWI)
 - Injects water into burner section to reduce peak combustion temperatures and reduce NOx

NOx Reduction

High Pressure Water Injection (HPWI)

- PROS
 - PROVEN technology
 - Simple Installation / packaged system
 - Small installation footprint
 - Low capital cost
 - Low Operations & Maintenance Costs
 - Only consumable is DI water and filters
 - Power increase (~7%) due to increased mass flow
 - Reduces **Opacity**


NOx Reduction

- High Pressure Water Injection (HPWI)
- CONS
 - Increases CO
 - *NOTE: CO for Liquid fuel w/ HPWI is < CO for Gas w/ No HPWI*
 - Need reliable source for DI water
 - Large Tank, or
 - Smaller tank and on-site DI Water Processing System
 - (Requires about 20 GPM per engine)
 - If you have a Gas only FT4, requires dual fuel manifolds
 - Water flow limited by fuel system nozzle capacity

NOx Reduction

NOx and CO vs. WATER INJECTION

FT4A-9 BASE LOAD OPERATION



NOTE: These typical NOx and CO curves reflect composite test data collected from numerous FT4 engines. Actual results will vary based on engine load, material condition, exhaust temperature, fuel grade/quality, ambient temperature, humidity, etc.

Packaged HPWI System



I/O



I/O



← 480 VAC

← 125 VDC

← Control Air



Seaworthy/PEPCO Packaged HPWI


- Uses VFDs and Positive Displacement Pumps
 - Very fine water flow control
 - Smooth water flow change transitions
 - Lower pump discharge pressures
- Designed for minimal site interface requirements
- Interfaces with OEM and retrofitted control systems
- All wetted parts stainless steel
- Welded pipe & flange construction designed for strength & maintainability
- **100% factory tested – Typical Twin Pak commissioning one (1) day.**

ROI (Return On Investment)


HPWI may pay for itself!

- Reserve Market Pricing (CT typical) of **\$14,000/MW/month**
- Nominal **7%** power increase on a **20MW** unit is **1.4 MW**
- Therefore, **1.4 MW x \$14,000/MW/Mo x 12 mo = \$235,200 / year income**

Main Screen




Water Forwarding



Alarms & Trips

Unit 1 HPWI Alarms and Trips

Unit 1



Trips	1A	1B
86E Tripped		
86M Tripped		
Drive Fault		
Emergency Stop		
HMI EStop		
Hi Press Trip >850#		
Fail to build Press		
Water Flow LO LO		
Water Flow HI HI		
Inlet Vlv Fail to Open		
Both Fwd Pmps Failed		
Loss of 5psi Inlet Press		
Hi Conductance		
Inlet Vlv Shut in Run		
Loss of Press in Run		
Skid Comm Loss		
TT2 Loss		
TT7 Loss		
Water Flow Input Loss		
Water Press Input Loss		
Fuel Flow Loss		

Reset 1A
Reset 1B

Unit 1 Alarms	1A	1B
Water Flow HI		
Water Flow LO		
Hi Press >820#		
MW Loss		
Fuel Flow Loss Liquid		
Fuel Flow Loss Gas		

Common Alarms

Inlet Filter DP >15#		
Loss of DP Input		
DI Tank Level Lo		
DI Tank Level Lo Lo		
Loss of Tank Lvl Input		
Inlet Conductance Hi		
Loss of Cond Input		
1st Fwding Pmp Failure		
Shutdown Override		

Unit 1 HPWI

View Water Fwd


Unit Select

HPWI Trends 1A


HPWI Trends 1B

Unit 1 HPWI Alarms and Trips
U1_HPWI_Alarms
12:21 PM
2/12/2004


Shutdown Override



Redundant HPWI System



Redundant HPWI System



Seaworthy/PEPCO Packaged HPWI

The Bottom Line

- Simple, very effective design
- Very Low maintenance
 - No mechanical throttling / no wear
 - Field proven Industrial components
- Cost effective

Combination Removal/Reduction

Many SCR systems use a reduction technology, such as HPWI, to reduce the more expensive SCR requirements and reach lower emissions limits.

Contact Information:

Seaworthy Industrial Systems, Inc.

22 Main St.

Centerbrook, CT 06409

Phone: (860) 767-3095

FAX: (860) 767-1263

Contact: Don Ricciuti / Matt Winkler

Email: dricciuti@seaworthysys.com / mwinkler@seaworthysys.com

PEPCO (Plainville Electrical Products Co.)

435 Lake Ave.

Bristol, CT 06010

Phone: (860) 583-1144

FAX: (860) 583-1421

Contact: Mike Cohn / Joe Nalley

Email: mike.cohn@pepco-ft4.com / jnalley@pepco-ft4.com

Website: www.pepco-ft4.com



